
## Maintenance


Isolate the flow and return to the blending valve and partially drain down the manifold

To clean or replace the internals of the blending valve, first remove the temperature control knob from the top of the valve. The temperature cam also needs to be removed by sliding it off the brass headwork.



Installation and Maintenance Instructions

# **Pump Mixer Set**




The thermostatic controller provides temperature controlled mixed water to an underfloor heating system with a heat output up to 14kW.

#### Technical Specifications & Dimensions:

Maximum static pressure: 10 bar Maximum temperature: 85°C 35°C to 60°C

45°C (Control knob is in the adjustable position) Factory pre-set:

Dimensions:



All dimensions in mm unless otherwise stated

# Wiring

To comply with IEE regulations, the pump on the Manifold Control Pack must be provided with an earth. All wiring should be undertaken by a qualified installer and must conform to IEE regulations.

# Commissioning

To protect and prevent damage to the blending valve and other devices in the heating circuit, it is recommended that the connecting pipe work is thoroughly flushed to remove any debris before filling and venting the system.

Close the manifold isolating valves, with the system filled and pressurised, vent the control unit via the air vent on the pump outlet elbow.

Open the manifold isolating valves and other valves and vent via the air vent again. With the primary pipework to the boiler, the control unit and manifolds both filled and at the correct system operating pressure it is important to check all joints for any leakage.

With timber floor finishes including strip laminate products the maximum floor temperature of 27°C should not be exceeded as this may result in excessive shrinkage of the material.

Maximum temperatures can vary so check the floor manufacturers

Recommendations first

To adjust the temperature simply rotate the temperature control handle clockwise or anti-clockwise as indicated on the cap, until you reach the required setting.




To measure the mixed water temperature use a

measure the surface temperature on the pump outlet elbow. Adjust the temperature as specified for the

# Left-right interchange function

The mixer comes from the factory to fit the left-hand side of the manifold. This can easily be changed to the right-hand side. First take the bottom part of the mixer (with the temperature control), then remove the attached fitting from the right side of the casing. Inside you will see a hexagon female fitting. With the brass hexagon fitting in the box provided unscrew the end part of the casing and fit to the left-hand side making sure you seal the threads.( easier to do if fitted in a vice) Re-fit to the fitting so that the bottom part is now complete.



5

### Pack Contents:

PLEASE CHECK CONTENTS OF PACK BEFORE BEGINNING INSTALLATION. Description, Part Number and Quantity

Water supply system components(11/2\*F\*1M)

Flat gasket (45\*33\*3)

Flat gasket (45\*33\*3)

Mixed water system components (11/2"F\*1"M\*3/4"F)

Connection elbow (3/4"F"3/4M)



Designed to work with manifolds of all types, on 210mm centres. The thermostatic blending valve is a bolt on unit providing a guick and simple system to install

The thermostic blooding value is the cost of the control system. It is used with flow and relation manifolds to control the flow interpretation of values to the funderflow heating pipework. If mixes the hot value in the boiler and supplies the water back to the surface pipe at the correct temperature. The mixing value operates at a lower temperature than the radiator system, between 35°C and 60°C depending on the construction of the floor. The water supply temperature can be adjusted according to the structure of the floor.

#### Installation:

Firstly firmly fix the distribution manifolds to the wall leaving enough room beside the manifold to fit the control pack (see dimensions on Page 1). Before beginning the installation of the Thermonik Underfloor Heating Control Pack, identify all of the components

3




1.1 Install the flat gasket into the connecting nut 1.1 install the hat gasket into the connecting out of the water-mixing system component, and then match the connecting nut with the external thread of the water pump and tighten it. Ensure that the mixing system components, flat gaskets and pumps are in a seal fit state (note the direction arrow on the pump body).

1.2 Install the gasket into the connecting nut of the water supply system component, and then match the connecting nut with the external thread of the water pump and tighten it. Ensure that water supply system components, gaskets and pumps are in a seal fit.

the mixing system and supply system, rotate its 1" male threads into the main bar or 1" female threads of other control unit, use the cone ring or other sealing winding belt of the tubes to tighten and seal, then re-rotate the free nut of the union into the mixing system and supply system correctly to avoiding leaking.

If the primary circuit serving the underfloor heating is not fitted with an automatic bypass valve, it is recommended that one is installed across the flow and return pipes, that one is installed across the flow and return pipes, improve system efficiency.



2